

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Admirals Beach	Admiral's Beach	2 Well Fields	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 26, 2004 for the following reason: Chlorination system is turned off by operator, due to taste (Please contact our regional Medical Officer of Health for more information).</p>				
Badger	Badger	Well Field, 2 wells on standby	97	excellent
Baine Harbour	Baine Harbour	Dug	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 14, 2003 for the following reason: Water supply has no disinfection system (Please contact our regional Medical Officer of Health for more information).</p>				
Barachois Brook	Barachois Brook	Drilled	100	excellent
Bay Roberts	Bay Roberts, Spaniard's Bay	Rocky Pond	97	excellent
Bay St. George South	Heatherton	#1 Well Heatherton (Home Hardware)	86	good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - TDS, SULPHATE, MANGANESE (Please see Tap Water report for details).</p>				
Bay St. George South	Highlands	#2B Well Highlands (Mr. MacPherson)	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 9, 2009 for the following reason: Insufficient residual disinfectant in water system disinfected by means other than chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Bay St. George South	Highlands	Pumphrey Well Highlands	93	very good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Bay St. George South	Jeffrey's	#1 Well Jeffrey's (Joe Curnew)	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - TDS (Please see Tap Water report for details).</p>				
Bay St. George South	Jeffrey's	#2 Well Jeffrey's (Calvin Madore)	100	excellent
Bay St. George South	Jeffrey's	#3 Well Jeffrey's (Sid Shears)	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Bay St. George South	Lock Leven	#6 Well Loch Leven (Jerry Quilty)	92	very good
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p>				
Bay St. George South	McKay's	#2B Lions Club Well	86	good
Bay St. George South	McKay's	#7 Well McKay's (Gordon Hulan)	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Bay St. George South	Robinson's	#1 Well Robinson's (Louie MacDonald)	100	excellent
Bay St. George South	St. Fintan's	#2 Well St. Fintan's (Louis King)	100	excellent
Bay St. George South	St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	100	excellent
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	100	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Black Duck	Black Duck (Siding)	#1 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 21, 2000 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 144.3 ug/l (Please see HAA report for details).</p>				
Blaketown	Blaketown	#2 Daphne Pincet Well	100	excellent
Blaketown	Blaketown North	#4 Hilda Barrett Well	97	excellent
Blaketown	Blaketown South	#1 Selby Mercer Well	100	excellent
Brigus South	Dunphey's Hill area	#2 Well Dunphey's Hill	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 3, 2003 for the following reason: Chlorination system is turned off by operator due to taste (Please contact our regional Medical Officer of Health for more information).</p>				
Brigus South	Forge Hill area	#1 Well Forge Hill	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 3, 2003 for the following reason: Chlorination system is turned off by operator due to taste (Please contact our regional Medical Officer of Health for more information).</p>				
Brigus South	Near highway	#3 Well Main Road	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 3, 2003 for the following reason: Chlorination system is turned off by operator due to taste (Please contact our regional Medical Officer of Health for more information).</p>				
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 18, 2007 for the following reason: Water distribution system is undergoing maintenance (Please contact our regional Medical Officer of Health for more information).</p>				
Bunyan's Cove	Bunyan's Cove	#1 Well	92	very good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, IRON, MANGANESE (Please see Tap Water report for details).</p>				
Bunyan's Cove	Bunyan's Cove	#2 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 20, 2006 for the following reason: Inadequately treated water was introduced into the system due to fireflows, flushing operations, minor power outage or other pressure loss. (Please contact our regional Medical Officer of Health for more information).</p>				
Canning's Cove	Centre Canning's Cove	#3 Well - Glenda Penney	100	excellent
Canning's Cove	Lower Canning's Cove	#1 Well - Pleman Pitts	100	excellent
Canning's Cove	Upper Canning's Cove	#2 Well - Eugene Ellis	100	excellent
Cartwright	Cartwright	Burdett's Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p>				
<p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 23, 2006 for the following reason: Inadequately treated water was introduced into the system due to fireflows, flushing operations, minor power outage or other pressure loss (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Cavendish	North Side Cavendish	#1 Well - Max Bishop	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 9, 2001 for the following reason: Insufficient Chlorine in Water Supply (Please contact our regional Medical Officer of Health for more information).</p>				
Cavendish	North Side Cavendish	#2 Well - Tom Critch	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 10, 2003 for the following reason: Disinfection off for maintenance (Please contact our regional Medical Officer of Health for more information).</p>				
Chance Cove	Back Cove Area	Olive Smith Well	100	excellent
Chance Cove	Lower Cove East	Albert Rowe Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 14, 2009 for the following reason: Disinfection system is off due to maintenance or mechanical failure. (Please contact our regional Medical Officer of Health for more information).</p>				
Chance Cove	Lower Cove Point	Eugene Smith Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: BARIUM (Please see Tap Water report for details).</p>				
Chance Cove	New Housing Area	New Housing Area Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: ARSENIC (Please see Tap Water report for details).</p>				
Chance Cove	Upper Cove Centre	Angus Brace Well	97	excellent
Chance Cove	Upper Cove South	Edgar Crann Well	97	excellent
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 28, 2009 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).</p>				
Churchill Falls	Churchill Falls	Smallwood Reservoir	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 8, 2009 for the following reason: Jun 8, 2009 - Partial - Machine Shop, Warehouse #1 - Disinfection system is off due to maintenance or mechanical failure (Nov 6, 2008); (Please contact our regional Medical Officer of Health for more information).</p>				
Clareville	Clareville, Shoal Harbour	Shoal Harbour River	95	excellent
Clarke's Beach	Otterbury	#1 Well - Quinlon Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Clarke's Beach	Otterbury	#2 Well - Delaney Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Colliers	Harbour Drive	#5 Well - Whalen's Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 25, 2009 for the following reason: Water entering the distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact our regional Medical Officer of Health for more information).</p>				
Colliers	Harbour Drive & Main Road	#3 Well - Griffin's Well	100	excellent
Colliers	Main Road	#1 Well - Mahoney's Well	100	excellent
Colliers	Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 25, 2009 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).</p>				
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	97	excellent
Conception Harbour	Cemetery Road & Main Road	Cemetery Road Well	100	excellent
Conception Harbour	Healey's Pond Rd, Old Rd & Main Rd	Healey's Pond Road Well	97	excellent
Conception Harbour	Lower Bacon Cove	Lower Bacon Cove Well	100	excellent
Conception Harbour	Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	100	excellent
Corner Brook	Corner Brook (All of eastside, portion of westside) (+Massey Drive)	Trout Pond, Third Pond (2 intakes)	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 131.75 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 188.8 ug/l (Please see HAA report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 12, 2009 for the following reason: Partial - Aug 12, 2009 - Westside Area Starting from Corner Brook Stream Including Elizabeth St. Area. - Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).</p>				
Cox's Cove	Upper Area	Upper Area Well #1	97	excellent
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p>				
Deep Bight	Deep Bight	Deep Bight Well Field	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 14, 2006 for the following reason: Inadequately treated water was introduced into the system due to fireflows, flushing operations, minor power outage or other pressure loss. (Please contact our regional Medical Officer of Health for more information).</p>				
Deer Lake	Deer Lake (+Reidville)	Humber Canal, Grand Lake	94	very good
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p> <p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR (Please see Tap Water report for details).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Dildo	Hill Road Area	#2 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Eastport	Eastport (+Sandy Cove)	Dug	95	excellent
Fermeuse	Fermeuse	Port Kirwan Road Well	100	excellent
Flat Bay	Flat Bay (East)	#1 Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: ARSENIC (Please see Tap Water report for details).</p>				
Flat Bay	Flat Bay (East)	#2 Well	100	excellent
Flat Bay	Flat Bay (East)	#3 Well	100	excellent
Flat Bay West	Birchy Brook - Federation of Indians	#1 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 2, 2005 for the following reason: Chlorination system is turned off by operator due to lack of funds to operate (Please contact our regional Medical Officer of Health for more information).</p>				
Flat Bay West	Flat Bay West - Federation of Indians	#3 Well	100	excellent
Forteau	Forteau	Trout Brook	100	excellent
Fox Roost-Margaree	Fox Roost-Margaree	Drilled 8 inch	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 91 ug/l (Please see HAA report for details).</p>				
Frenchman's Cove	Frenchman's Cove	Dug Well	91	very good
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p>				
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR (Please see Tap Water report for details).</p>				
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: ARSENIC (Please see Tap Water report for details).</p>				
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Gander	Gander	Gander Lake	Not Given	Not Ranked
<p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 99.8 ug/l (Please see HAA report for details).</p>				
Georgetown	Georgetown	Drilled	97	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 123.5 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 143.3 ug/l (Please see HAA report for details).</p>				
Grates Cove	Grates Cove Centre	#1 Cyril Meadus Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Grates Cove	Grates Cove North End	#2 Frank Janes Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Great Codroy	Great Codroy East	#1 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 21, 2000 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Great Codroy	Great Codroy West	#2 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 22, 2000 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	100	excellent
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	100	excellent
Harbour Grace	Harbour Grace South	Southside Well	100	excellent
Harbour Grace	Riverhead	Mercer's Rd. Well	97	excellent
Harbour Grace	Thickett	#1 Thicket Susie Galway Well	100	excellent
Harbour Grace	Thickett	#2 Thicket New Well	100	excellent
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	100	excellent
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	100	excellent
Harcourt-Monroe-Waterville	Harcourt-Monroe-Waterville	Developed Spring	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 12, 2003 for the following reason: Insufficient chlorine residual entering system (Please contact our regional Medical Officer of Health for more information).</p>				
Harry's Harbour	Harry's Harbour	#1 Well - Northeast Well	100	excellent
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 9, 2009 for the following reason: Total coliforms detected and confirmed in repeat samples (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Harry's Harbour	Harry's Harbour	#3 Well - South Well	100	excellent
Hodge's Cove	Hodge's Cove	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 22, 2009 for the following reason: Water entering the distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact our regional Medical Officer of Health for more information).</p>				
Holyrood	Holyrood	Main Line	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Holyrood	Holyrood	O'Connell's Well	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Holyrood	Holyrood	Woodford Station - Healey's Well and Quinlan's Well	100	excellent
Hopeall	Gilberts Hill	Gilberts Hill Well	100	excellent
Hopeall	Hopeall	Charles Cumbly Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 14, 2001 for the following reason: Disinfection system is off due to maintenance or mechanical failure. (Please contact our regional Medical Officer of Health for more information).</p>				
Hopedale	Hopedale	American Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p>				
<p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 25, 2009 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).</p>				
Jackson's Cove-Langdon's Cove-Silverdale	Jackson's Cove - East End	#2 Well - Jackson's Cove	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 13, 2008 for the following reason: Chlorination system is turned off by operator, due to perceived health risk - Operator not available, regular chlorine test not performed (Please contact our regional Medical Officer of Health for more information).</p>				
Jackson's Cove-Langdon's Cove-Silverdale	Jackson's Cove - Northwest End	#1 Well - Jackson's Cove	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 13, 2008 for the following reason: Chlorination system is turned off by operator, due to perceived health risk - Operator not available, regular chlorine test not performed (Please contact our regional Medical Officer of Health for more information).</p>				
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 13, 2008 for the following reason: Chlorination system is turned off by operator, due to perceived health risk - Operator not available, regular chlorine test not performed (Please contact our regional Medical Officer of Health for more information).</p>				
Jean de Baie	Jean de Baie	#1 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 1, 1996 for the following reason: Chlorination not being provided lack of funds (Please contact our regional Medical Officer of Health for more information).</p>				
Kippens	Kippens	Well Field	100	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
L'Anse au Clair	L'Anse au Clair	Park Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 27, 2005 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Labrador City	Labrador City	Beverly Lake	100	excellent
Lance Cove	Lance Cove	Local Service District Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 5, 2003 for the following reason: Chlorination system is turned off by operator due to taste or other aesthetic considerations. (Please contact our regional Medical Officer of Health for more information).</p>				
Makinsons	Hodgewater Line East & Juniper Stump	Taylor's Wells	100	excellent
Makinsons	Turkswater & Hodgewater Line West	Country Path Wells	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Makkovik	Makkovik	Ranger Bight Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Mary's Harbour	Mary's Harbour	St. Mary's River	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Marysvale	Marysvale, Long Pond	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 1, 2008 for the following reason: Water entering the distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3mg/l or equivalent CT value (Please contact our regional Medical Officer of Health for more information).</p>				
Mattis Point	Mattis Point	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 9, 2003 for the following reason: Disinfection system is off due to repairs needed on distribution system (Please contact our regional Medical Officer of Health for more information).</p>				
McCallum	McCallum	Drilled	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 215.75 ug/l (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 10, 2009 for the following reason: Total coliforms detected and confirmed in repeat sample. (Please contact our regional Medical Officer of Health for more information).</p>				
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	95	excellent
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Nain	Nain	Nain Brook and Anainik's Pond	95	excellent
TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.				
Natuashish	Natuashish (Sango Bay)	Well Field	95	excellent
North Harbour	North Harbour North End, tap outlet	Communal Well	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 15, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).				
North West Brook-Ivany's Cove	North West Brook, Ivany Cove	#1 Well - Cabot Road South Well	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 22, 2007 for the following reason: inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss (Please contact our regional Medical Officer of Health for more information).				
North West Brook-Ivany's Cove	North West Brook, Ivany Cove	#2 Well	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on October 9, 2008 for the following reason: No free chlorine residual detected in the water distribution system (Please contact our regional Medical Officer of Health for more information).				
North West Brook-Ivany's Cove	North West Brook, Ivany Cove	#3 Well - Harbour Well	97	excellent
North West River	North West River	Wellfield (#1 & #3 Well) + #2 Well	100	excellent
O'Donnells	O'Donnell's	Well Field	97	excellent
AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).				
Paradise	Paradise	Bay Bulls Big Pond	97	excellent
Petley	Petley	Drilled	100	excellent
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 2, 2002 for the following reason: unsatisfactory chlorine residual results (Please contact our regional Medical Officer of Health for more information).				
Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	Not Given	Not Ranked
THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 292.5 ug/l (Please see THM report for details).				
HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 274.8 ug/l (Please see HAA report for details).				
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 25, 2009 for the following reason: Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).				
Port Kirwan	North Side	Dug Well / Drilled Well	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Insufficient Chlorination Residual & Total Coliform (Please contact our regional Medical Officer of Health for more information).				
Port Rexton	Champneys Arm	Champney's Arm Well	Not Given	Not Ranked
BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 21, 2001 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Port Rexton	Hunchback Hill	#3 Well - Harold Vivian's Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 21, 2001 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Port Rexton	Port Rexton	#1 Well - Lois Long Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 21, 2001 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Port Rexton	Ship Cove	#5 Well - Mabel Clarke's Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 21, 2001 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Port Rexton	Ship Cove	#6 Well - Banister's Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 21, 2001 for the following reason: Lack of Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Port au Choix	Port au Choix	Well Field	91	very good
<p>TURBIDITY: A turbidity exceedance was detected in the last tap sample. Increased turbidity of drinking water results in it being less aesthetically pleasing, and may interfere with the disinfection process. Please see Tap Water report for more details.</p> <p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, IRON (Please see Tap Water report for details).</p>				
Port au Port East	Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	100	excellent
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#4-Goose Pond Road Well	100	excellent
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#5 Ocean View Drive Well	100	excellent
Port au Port West-Aguathuna-Felix Cove	Port au Port West, Aguathuna	#1 & #3 Drilled	97	excellent
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Postville	Postville	Big Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to an inadequate number of HAA samples to compare to the current HAA guideline. (Please see HAA report for details).</p>				
Raleigh	Raleigh	#4 Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on January 5, 2004 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Red Bay	Red Bay	Northern Brook	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 1, 1994 for the following reason: Unsatisfactory Bacteriological Results (Please contact our regional Medical Officer of Health for more information).</p>				
Red Harbour	Red Harbour	Drilled	100	excellent
Renews-Cappahayden	Cappahayden	#1 Dinn's Well	100	excellent

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Rigolet	Rigolet	Rigolet Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 357.5 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 401.3 ug/l (Please see HAA report for details).</p>				
Riverhead	Riverhead (St. Mary's Bay)	Well Field	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Inadequate Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Sandringham	Sandringham	Drilled	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - PH (Please see Tap Water report for details).</p>				
Sandy Cove	Sandy Cove	Dug	95	excellent
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to an inadequate number of THM samples to compare to the current THM guideline. (Please see THM report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on August 17, 2005 for the following reason: Water supply has no disinfection system (Please contact our regional Medical Officer of Health for more information).</p>				
Sheaves Cove	Sheaves Cove	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 8, 2008 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Sheppardville	Sheppardville	Drilled	100	excellent
Sheshasheits	Sheshasheits - Indian Band Council	Wells 1, 2 & 3	96	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove East	#3 Well - Bernard Brake Well	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: TURBIDITY, LEAD (Please see Tap Water report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 21, 2000 for the following reason: No Chlorine Detected in System (Please contact our regional Medical Officer of Health for more information).</p>				
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 21, 2000 for the following reason: No Chlorine Detected in System (Please contact our regional Medical Officer of Health for more information).</p>				
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead	#4 Well - Leonard King Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Disinfection system is off, due to maintenance or mechanical failure. (Please contact our regional Medical Officer of Health for more information).</p>				
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#7 Well - Gin Badcock Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#9 Well - Walter Reynolds Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point Birch Hill Road	#10 Well - Les Gover Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				
South Brook	South Brook	Next to Brook	100	excellent
South Dildo	South Dildo	#5 Well - Calvin Reid Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on May 6, 2003 for the following reason: Disinfection system is off due to maintenance or mechanical failure (Please contact our regional Medical Officer of Health for more information).</p>				
Springdale	Springdale Industrial Park	Well	100	excellent
St. Alban's	St. Alban's	Well Field	97	excellent
St. Andrews	Air Strip Road	#4 Well Strip Road Well	88	good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
St. Andrews	St. Andrew's	#1 Well	100	excellent
St. Andrews	St. Andrew's	#2 Well	91	very good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
St. Andrews	St. Andrew's East	#3 Well	100	excellent
St. John's	St. John's	Windsor Lake	100	excellent
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	95	excellent
St. John's	St. John's - Goulds	Barton's Road Well	100	excellent
St. Joseph's	St. Joseph's S.M.B.	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: No Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
St. Lewis	St. Lewis	Tub Harbour Pond	Not Given	Not Ranked
<p>THM: Drinking water quality was NOT ranked due to the presence of the following THM value which exceeds the current guideline. THM Average = 295 ug/l (Please see THM report for details).</p> <p>HAA: Drinking water quality was NOT ranked due to the presence of the following HAA value which exceeds the current guideline. HAA Average = 253.8 ug/l (Please see HAA report for details).</p>				
St. Lunaire-Griquet	St. Lunaire-Griquet	Drilled	86	good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, TDS, IRON, MANGANESE (Please see Tap Water report for details).</p>				
St. Mary's	St. Mary's	Wellfield	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 31, 2008 for the following reason: Water entering the distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact our regional Medical Officer of Health for more information).</p>				
St. Patricks	St. Patricks	David Joy Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on February 20, 1991 for the following reason: No Chlorinator (Please contact our regional Medical Officer of Health for more information).</p>				
Stephenville	Stephenville	Well Field	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on November 20, 2009 for the following reason: Partial - College of the North Atlantic L.A. Bown Campus - Water distribution system is undergoing maintenance or repairs. (Please contact our regional Medical Officer of Health for more information).</p>				
Stephenville Crossing	Stephenville Crossing	Well Fields 1 & 2	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on December 21, 2009 for the following reason: Partial - Brook Street, West Street and all streets in between - Disinfection system is off due to maintenance or mechanical failure. (Please contact our regional Medical Officer of Health for more information).</p>				
Swift Current	Swift Current	Drilled	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on April 30, 1999 for the following reason: No Chlorination (Please contact our regional Medical Officer of Health for more information).</p>				
Tompkins	Tompkins	Greg Wall Well	97	excellent
Upper Amherst Cove	Upper Amherst Cove	Drilled	97	excellent
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - MANGANESE (Please see Tap Water report for details).</p>				
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 13, 2003 for the following reason: No free chlorine residual detected in the system (Please contact our regional Medical Officer of Health for more information).</p>				
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on March 21, 2006 for the following reason: Water entering the distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value. (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIassac Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 8, 2003 for the following reason: No free chlorine residual detected in the system (Please contact our regional Medical Officer of Health for more information).</p>				
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on September 19, 2006 for the following reason: No free chlorine residual detected in the system (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	#3 Yard West Mines Road	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	#4-West Mines Road	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Davidson Avenue	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Fancy Hill Main Street	Not Given	Not Ranked
<p>CONTAMINANT: Drinking water quality was NOT ranked due to the presence of the following contaminants in the last tap sample: TURBIDITY, ARSENIC (Please see Tap Water report for details).</p> <p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Kavanagh's Lane	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Kelloway's Memorial St.	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Main Street	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Middleton Ave	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating chlorine residual (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Normore Crescent East #1	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	Quigley's Line	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				

Drinking Water Quality Index Summary for Public Water Supplies in Newfoundland and Labrador

Community Name	Serviced Area(s)	Source Name	WQI	DWQI Ranking
Wabana	Wabana	Scotia #1	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabana	Wabana	St. Edward's Memorial St.	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on June 23, 2000 for the following reason: Fluctuating Residual and interconnection (Please contact our regional Medical Officer of Health for more information).</p>				
Wabush	Wabush	Wahnahnish Lake	97	excellent
West St. Modeste	West St. Modeste	Well Field	82	good
<p>AESTHETIC: The perceived water quality may be lower due to the exceedance of the following aesthetic parameters in your last tap sample: - COLOR, IRON, MANGANESE (Please see Tap Water report for details).</p>				
William's Harbour	William's Harbour	Beaver Pond	Not Given	Not Ranked
<p>BOIL WATER ADVISORY: Drinking water quality was NOT ranked due to the presence of a Boil Water Advisory issued on July 7, 2000 for the following reason: Community will not chlorinate (Please contact our regional Medical Officer of Health for more information).</p>				
Winterland	Winterland	Well Field	100	excellent
Totals:		202		

A Drinking Water Quality Index (DWQI) is a means to summarize water quality data into simple terms (e.g. good) for reporting to the public in a consistent manner. Similar to the UV index or an air quality index, it tells us, in simple terms, what the quality of drinking water is from your drinking water supply.

Essentially the DWQI is calculated by comparing the water quality data to the Guidelines for Canadian Drinking Water Quality. This calculation produces a score between 0 and 100. A higher score means a better quality of drinking water. The scores are then ranked into one of the six categories described below:

Excellent: (DWQI Value 95-100) - Water quality is protected with a virtual absence of impairment; conditions are very close to pristine levels; these index values can only be obtained if all measurements meet recommended guidelines virtually all of the time.

Very Good: (DWQI Value 89-94) - Water quality is protected with a slight presence of impairment; conditions are close to pristine levels.

Good: (DWQI Value 80-88) - Water quality is protected with only a minor degree of impairment; conditions rarely depart from desirable levels.

Fair: (DWQI Value 65-79) - Water quality is usually protected but occasionally impaired; conditions sometimes depart from desirable levels.

Marginal: (DWQI Value 45-64) - Water quality is frequently impaired; conditions often depart from desirable levels.

Poor: (DWQI Value 0-44) - Water quality is almost always impaired; conditions usually depart from desirable levels.