

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Admirals Beach	Admiral's Beach	2 Well Fields	SJ	GW	185	Oct 13, 2010	A	Water Supply has no disinfection system.
Aquaforte	Aquaforte	Davies Pond	SJ	SW	46	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Aquaforte	Aquaforte	Davies Pond	SJ	SW	46	Jun 23, 2000	F3	Total coliforms detected and confirmed in repeat sample.
Baie Verte	Baie Verte	Baie Verte River	Gan	SW	1275	Jul 06, 2009	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Baine Harbour	Baine Harbour	Baine Harbour Pond	E	SW	74	Jun 01, 1995	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Baine Harbour	Baine Harbour	Dug	E	GW	52	Nov 14, 2003	A	Water Supply has no disinfection system.
Bartletts Harbour	Bartletts Harbour	Long Pond (same as Castors River North)	W	SW	136	Apr 29, 1998	E2	No free chlorine residual detected in the water distribution system.
Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	E	SW	255	Jun 02, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Bay de Verde	Bay de Verde	Island Pond	SJ	SW	396	Mar 22, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Beachside	Beachside	Long Pond	Gan	SW	174	Apr 29, 2011	C2	Disinfection system is off, due to lack of chlorine or other disinfectant.
Bear Cove	Bear Cove	Lower Bear Cove	W	GW	20	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Bear Cove	Bear Cove	Upper Bear Cove	W	GW	9	Jun 22, 2000	E2	No free chlorine residual detected in the water distribution system.
Bellevue	Bellevue	Big Pond	E	SW	148	Jun 08, 2011	D1	Water distribution system is undergoing maintenance or repairs.
Bellevue Beach	Bellevue Beach	Unnamed Brook	E	SW	80	Sep 18, 1997	E2	No free chlorine residual detected in the water distribution system.
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	W	GW	0	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Benoit's Siding	Doyles	# 2 Well Doyles	W	GW	15	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Bird Cove	Bird Cove (+Brig Bay)	Inner Gilmour Pond	W	SW	137	Aug 02, 2011	E2	No free chlorine residual detected in the water distribution system.
Biscay Bay	Biscay Bay	Unnamed Pond	SJ	SW	38	Jun 23, 2000	A	Water Supply has no disinfection system.
Black Duck	Black Duck (Siding)	#1 Well	W	GW	25	Jun 21, 2000	A	Water Supply has no disinfection system.
Black Duck	Black Duck (Siding)	#2 Well	W	GW	29	Jun 22, 2000	B1	Chlorination system is turned off by operator, due to taste.
Black Duck Cove	Black Duck Cove	Long Pond - Black Duck Cove Intake	W	SW	125	Dec 17, 1997	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	L	SW	0	Jan 11, 2011	Z	None Listed
Blaketown	Blaketown	#2 Daphne Pincent Well	SJ	GW	89	May 14, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Bonavista	Bonavista	Long Pond	E	SW	3764	May 18, 2012	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Branch	Branch	Valley Pond	SJ	SW	72	Jan 01, 1989	A	Water Supply has no disinfection system.
Brent's Cove	Brent's Cove	Paddy's Pond	Gan	SW	204	Feb 20, 1991	E2	No free chlorine residual detected in the water distribution system.
Brig Bay	Brig Bay	Inner Gilmour Pond	W	SW	40	Aug 02, 2011	E2	No free chlorine residual detected in the water distribution system.
Brigus	Brigus (+Cupids, +South River)	Brigus Long Pond (to Brigus)	SJ	SW	659	Apr 09, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Brigus South	Dunphey's Hill area	#2 Well Dunphey's Hill	SJ	GW	30	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Brigus South	Forge Hill area	#1 Well Forge Hill	SJ	GW	25	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Brigus South	Near highway	#3 Well Main Road	SJ	GW	26	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Britannia	Britannia		E			Aug 02, 2010	E2	No free chlorine residual detected in the water distribution system.
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	SJ	GW	279	Jun 18, 2007	D1	Water distribution system is undergoing maintenance or repairs.
Buchans Junction	Buchans Junction	Lapland Pond	Gan	SW	96	Aug 12, 2011	F3	Total coliforms detected and confirmed in repeat sample.
Bunyan's Cove	Bunyan's Cove	#2 Wellfield	E	GW	39	May 23, 2006	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Burgeo	Burgeo	Long Pond	W	SW	1607	May 07, 2010	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Burgeo	Burgeo	Long Pond	W	SW	1607	Aug 14, 2001	E2	Partial - Sandbanks Park - No free chlorine residual detected in the water distribution system.
Burlington	Burlington	Eastern Island Pond	Gan	SW	376	Dec 24, 2010	D1	Water distribution system is undergoing maintenance or repairs.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Calvert	Calvert		SJ		29	Jun 23, 2000	A	Water Supply has no disinfection system.
Campbellton	Campbellton	Indian Arm Brook	Gan	SW	474	Feb 27, 2012	C2	Disinfection system is off, due to lack of chlorine or other disinfectant.
Cape Freels North	Cape Freels North	Long Pond	Gan	SW	145	Mar 14, 2008	C1	Partial - - Disinfection system is off, due to maintenance or mechanical failure.
Cartwright	Cartwright	Burdett's Pond	L	SW	552	May 23, 2006	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Castor River North	Castor River North	Long Pond (same as Bartlett's Harbour)	W	SW	172	Jan 01, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Castor River South	Castor River South	Unnamed	W	SW	169	Jan 01, 1991	A	Water Supply has no disinfection system.
Cavendish	North Side Cavendish	#1 Well - Max Bishop	SJ	GW	32	May 09, 2001	E2	No free chlorine residual detected in the water distribution system.
Cavendish	North Side Cavendish	#2 Well - Tom Critch	SJ	GW	25	Jun 10, 2003	C1	Disinfection system is off, due to maintenance or mechanical failure.
Chanceport	Chanceport	Bridger's Cove Pond	Gan	SW	35	Aug 11, 1989	E2	No free chlorine residual detected in the water distribution system.
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	L	SW	168	Nov 25, 2011	D1	Water distribution system is undergoing maintenance or repairs.
Charlottetown (Labrador)	Charlottetown rec centre	Rec Centre Well	L	GW	4	Jun 09, 2009	A	Water Supply has no disinfection system.
Churchill Falls	Churchill Falls	Smallwood Reservoir	L	SW	634	Oct 14, 2008	A	Partial - Relay Building - Water Supply has no disinfection system.
Churchill Falls	Churchill Falls	Smallwood Reservoir	L	SW	634	Jun 08, 2010	C1	Partial - Airport Hanger & Terminal - Disinfection system is off, due to maintenance or mechanical failure.
Churchill Falls	Churchill Falls	Smallwood Reservoir	L	SW	634	Oct 30, 2008	C1	Partial - Machine Shop - Disinfection system is off, due to maintenance or mechanical failure.
Clarke's Beach	Otterbury	#1 Well - Quinlon Well	SJ	GW	19	Jun 23, 2000	A	Water Supply has no disinfection system.
Clarke's Beach	Otterbury	#2 Well - Delaney Well	SJ	GW	24	Jun 23, 2000	A	Water Supply has no disinfection system.
Conche	Conche	Martin's Brook	W	SW	225	May 18, 2001	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Conne River	Conne River	Southwest Brook	Gan	SW	837	Dec 13, 2011	C1	Disinfection system is off, due to maintenance or mechanical failure.
Cottrell's Cove	Cottrell's Cove	Cottrell's Pond	Gan	SW	151	Aug 27, 2009	F3	Total coliforms detected and confirmed in repeat sample.
Cox's Cove	Upper Area	Upper Area Wellfield	W	GW	60	Mar 15, 2011	D1	Water distribution system is undergoing maintenance or repairs.
Crow Head	Crow Head	Oars Pond	Gan	SW	205	Sep 04, 2008	C1	Disinfection system is off, due to maintenance or mechanical failure.
Cupids	Cupids	Brigus Long Pond (to Brigus)	SJ	SW	455	Apr 09, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Dildo	Hill Road Area	#2 Well	SJ	GW	91	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Eddies Cove West	Eddies Cove West	Unnamed	W	SW	72	Apr 09, 2003	A	Water Supply has no disinfection system.
Flat Bay	Flat Bay (East)	#1 Well	W	GW	78	Mar 05, 2010	B4	Chlorination system is turned off by operator, due to Non-consumption Order.
Flat Bay West	Birchy Brook - Federation of Indians	#1 Well	W	GW	32	Jun 21, 2000	A	Water Supply has no disinfection system.
Forresters Point	Forresters Point	Rudges Pond	W	SW	197	Nov 29, 1995	E2	No free chlorine residual detected in the water distribution system.
Forteau	Forteau	Trout Brook	L	SW	448	May 16, 2012	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Francois	Francois	Our Pond	W	SW	130	Apr 09, 1997	A	Water Supply has no disinfection system.
Freshwater·	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	SJ	GW	23	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Freshwater·	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	SJ	GW	44	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Gallants	Gallants	Gallant's Brook	W	SW	54	May 01, 1997	A	Water Supply has no disinfection system.
Gander Bay South	George's Point, Harris Point	Barry's Brook	Gan	SW	315	Oct 12, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Gaskiers	Gaskiers-Point La Haye	Big Hare Hill Pond	SJ	SW	290	Dec 22, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Gaultois	Gaultois	Piccaire Pond	Gan	SW	147	Oct 16, 2001	C1	Disinfection system is off, due to maintenance or mechanical failure.
George's Brook-Milton	George's Brook	George's Brook	E	SW	321	Mar 14, 2012	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
George's Brook-Milton	Milton	Lilly Pond	E	SW	348	Jul 29, 2011	F3	Total coliforms detected and confirmed in repeat sample.
Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	W	SW	120	Apr 03, 2012	D1	Water distribution system is undergoing maintenance or repairs.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Goobies	Goobies	Water Pond	E	SW	92	Apr 17, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Goose Cove East	Goose Cove East	Jack's Pond	W	SW	234	Aug 31, 1999	E2	No free chlorine residual detected in the water distribution system.
Grand Le Pierre	Grand Le Pierre	Nip Nose Pond	E	SW	264	Oct 10, 1997	E2	No free chlorine residual detected in the water distribution system.
Grates Cove	Grates Cove Centre	#1 Cyril Meadus Well	SJ	GW	98	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	SJ	GW	50	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Great Brehat	Great Brehat	Little Steady Pond	W	SW	103	Dec 17, 1997	E2	No free chlorine residual detected in the water distribution system.
Great Codroy	Great Codroy East	#1 Well	W	GW	67	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Great Codroy	Great Codroy West	#2 Well	W	GW	22	Jun 22, 2000	E2	No free chlorine residual detected in the water distribution system.
Green Island Brook	Green Island Brook	Green Island Brook	W	SW	193	Sep 11, 2007	E2	No free chlorine residual detected in the water distribution system.
Green Island Brook	Green Island Brook	Green Island Brook	W	SW	193	Sep 11, 2007	E2	No free chlorine residual detected in the water distribution system.
Green's Harbour	Green's Harbour West		SJ		0	Mar 14, 2001	A	Water Supply has no disinfection system.
Grey River	Grey River	Big Charlie's Pond	W	SW	125	Feb 20, 1997	A	Water Supply has no disinfection system.
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	L	GW	7572	May 17, 2012	D1	Partial - section of Hamilton River Road between Tenth Street and Palliser Crescent - Water distribution system is undergoing maintenance or repairs.
Harbour Grace	Riverhead	Mercer's Rd. Well	SJ	GW	43	Aug 04, 2011	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Head Pond	E	SW	176	Nov 20, 2003	A	Water Supply has no disinfection system.
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Head Pond	E	SW	176	Nov 20, 2003	F3	Total coliforms detected and confirmed in repeat sample.
Harcourt-Monroe-Waterville	Harcourt-Monroe-Waterville	Developed Spring	E	GW	40	Jun 12, 2003	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Hawke's Bay	Hawke's Bay	Torrent River	W	SW	391	May 18, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Heart's Desire	Heart's Desire	Terrence Pond	SJ	SW	226	Aug 11, 2010	D1	Water distribution system is undergoing maintenance or repairs.
Hopeall	Hopeall	Charles Cumby Well	SJ	GW	19	Mar 14, 2001	A	Water Supply has no disinfection system.
Hopeall	Gilberts Hill	Gilberts Hill Well	SJ	GW	30	Mar 14, 2001	A	Water Supply has no disinfection system.
Hopedale	Hopedale	American Pond	L	SW	530	Feb 15, 2012	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Howley	Howley	Sandy Lake	W	SW	241	Nov 01, 2002	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Howley	Howley	Sandy Lake	W	SW	241	Nov 01, 2002	F2	Total coliform or Escherichia (E. coli) detected AND repeat samples can not be taken as required.
Howley	Howley	Sandy Lake	W	SW	241	Nov 01, 2002	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
Indian Bay	Indian Bay	Indian Bay Brook	Gan	SW	196	Sep 26, 2008	F3	Total coliforms detected and confirmed in repeat sample.
Jackson's Cove-Langdon's Cove-Silverdale	Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Gan	SW	57	Dec 24, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Gan	GW	37	Apr 13, 2008	B2	Chlorination system is turned off by operator, due to perceived health risks.
Jean de Baie	Jean de Baie	Colleen's Pond (Back Up Supply)	E	SW	178	Jan 01, 1996	B2	Chlorination system is turned off by operator, due to perceived health risks.
Jean de Baie	Jean de Baie	#1 Well	E	GW	205	Jan 01, 1996	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
L'Anse au Clair	L'Anse au Clair	Park Pond	L	SW	226	Jan 07, 2010	Z	None Listed
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	L	SW	234	May 28, 2005	C1	Disinfection system is off, due to maintenance or mechanical failure.
La Poile	La Poile	Black Duck Pond	W	SW	111	Jan 01, 1995	B1	Chlorination system is turned off by operator, due to taste.
LaScie	La Scie	Stakes Pond	Gan	SW	955	Feb 20, 1991	A	Water Supply has no disinfection system.
Lamaline	Lamaline	Upper Hodges Pond	E	SW	79	Oct 24, 2011	D1	Water distribution system is undergoing maintenance or repairs.
Lance Cove	Lance Cove	Local Service District Well	SJ	GW	18	Aug 05, 2003	B1	Chlorination system is turned off by operator, due to taste.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Lance Cove	Lance Cove	Local Service District Well	SJ	GW	18	Aug 05, 2003	C2	Disinfection system is off, due to lack of chlorine or other disinfectant.
Lawn	Lawn	Brazil Pond	E	SW	705	Apr 05, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Little Bay	Little Bay	Mine Pond	Gan	SW	25	Aug 04, 2011	F2T	Total coliforms detected AND repeat samples can not be taken as required.
Little Bay	Little Bay	First Pond	Gan	SW	110	Dec 09, 2011	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Little Harbour East	Little Harbour East (Placentia Bay)	Unnamed Pond	E	SW	118	Jan 01, 1996	E2	No free chlorine residual detected in the water distribution system.
Little St. Lawrence	Little St. Lawrence	Butler's Brook (2 Intakes)	E	SW	122	May 23, 1999	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Long Harbour-Mount Arlington Heights	Long Harbour-Mount Arlington Heights	Shingle Pond and/or Trout Pond (2 Intakes)	SJ	SW	211	Oct 07, 2011	C1	Disinfection system is off, due to maintenance or mechanical failure.
Lower Lance Cove	Lower Lance Cove	Big Long Pond	E	SW	133	Aug 02, 2010	E2	No free chlorine residual detected in the water distribution system.
Main Brook	Main Brook	Joe Burt's Pond	W	SW	293	Jul 04, 2011	C1	Disinfection system is off, due to maintenance or mechanical failure.
Mainland	Mainland	Caribou Brook	W	SW	311	Sep 29, 2010	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
Mary's Harbour	Mary's Harbour	St. Mary's River	L	SW	417	May 14, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Marysvalle	Marysvalle, Long Pond	Drilled	SJ	GW	419	Feb 01, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Mattis Point	Mattis Point	Drilled	W	GW	136	Apr 10, 2003	C1	Disinfection system is off, due to maintenance or mechanical failure.
Middle Arm	Middle Arm	Dam Pond Brook	Gan	SW	517	Sep 15, 2008	C1	Disinfection system is off, due to maintenance or mechanical failure.
Miles Cove	Miles Cove	Paddock's Pond	Gan	SW	140	Sep 29, 2011	F4	Escherichia coli (E. coli) detected in an initial sample(s) is considered extensive and the water system has other known problems.
Morrisville	Morrisville	Morrisville Pond	Gan	SW	128	Aug 21, 2006	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Newman's Cove	Newman's Cove	Heale Pond Brook	E	SW	192	Mar 26, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Nippers Harbour	Nippers Harbour	Blackhead Pond Brook	Gan	SW	150	Nov 25, 1996	E2	No free chlorine residual detected in the water distribution system.
Norman's Cove-Long Cove	Norman's Cove-Long Cove	John Newhooks Pond	E	SW	773	Feb 02, 2012	D1	Partial - From Playground (adjacent to Bill Pitcher's Residence) to end of line - Water distribution system is undergoing maintenance or repairs.
North Harbour	North Harbour	Grandfather's Pond	E	SW	152	Jan 01, 1996	E2	No free chlorine residual detected in the water distribution system.
North Harbour	North Harbour North End, tap outlet	Communal Well	E	GW	6	Jun 15, 2000	A	Water Supply has no disinfection system.
Pacquet	Pacquet	Big Brook	Gan	SW	200	Feb 20, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Parkers Cove	Parkers Cove	Unnamed brook	E	SW	214	Dec 15, 2010	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Petit Forte	Petit Forte	Reddy's Pond	E	SW	97	Jan 01, 1996	C1	Disinfection system is off, due to maintenance or mechanical failure.
Petley	Petley	Drilled	E	GW	92	May 15, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Phillips Head	Phillips Head	Dogberry Brook	Gan	SW	142	Jul 28, 2006	F3	Total coliforms detected and confirmed in repeat sample.
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	W	SW	154	Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	W	GW	414	Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	W	GW	364	Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Pidgeon Cove-St. Barbe	Pigeon Cove	Long Pond (Intake #1)	W	SW	81	Aug 25, 1994	E2	No free chlorine residual detected in the water distribution system.
Plum Point	Plum Point	Grand Pond	W	SW	145	Dec 17, 1997	E2	No free chlorine residual detected in the water distribution system.
Point Lance	Point Lance	Unnamed Pond	SJ	SW	119	Jan 01, 1989	A	Water Supply has no disinfection system.
Point May	Point May	Short's Pond	E	SW	260	Apr 26, 2010	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Pollards Point	Pollards Point, Country Cove	Country Cove Pond	W	SW	354	Jan 01, 1987	A	Water Supply has no disinfection system.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Pollards Point	Pollards Point East	George Ricks Pond	W	SW		Jan 01, 1987	A	Water Supply has no disinfection system.
Pool's Cove	Pool's Cove	Widgeon Pond	Gan	SW	189	Sep 09, 1998	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Port Anson	Port Anson	Anchor Pond	Gan	SW	155	Aug 21, 2006	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Port Blandford	Port Blandford	Noseworthy's Pond	E	SW	521	May 10, 2012	F3	Total coliforms detected and confirmed in repeat sample.
Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	L	SW	509	Aug 06, 2010	D1	Water distribution system is undergoing maintenance or repairs.
Port Kirwan	North Side	Dug Well / Drilled Well	SJ	GW	37	Jun 23, 2000	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Port Kirwan	North Side	Dug Well / Drilled Well	SJ	GW	37	Jun 23, 2000	F3	Total coliforms detected and confirmed in repeat sample.
Port Rexton	Port Rexton	#1 Well - Lois Long Well	E	GW	7	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Port Rexton (Seasonal Use)	#2 Well - Edmund Brown's Well	E	GW	18	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Hunchback Hill	#3 Well - Harold Vivian's Well	E	GW	21	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Ship Cove	#5 Well - Mabel Clarke's Well	E	GW	18	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Ship Cove	#6 Well - Banister's Well	E	GW	3	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Champneys Arm	Champney's Arm Well	E	GW	27	Sep 21, 2001	A	Water Supply has no disinfection system.
Portugal Cove South	Portugal Cove South	Wrights Brook	SJ	SW	222	Jan 01, 1984	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Portugal Cove South	Portugal Cove South	Wrights Brook	SJ	SW	222	Jan 01, 1984	F3	Total coliforms detected and confirmed in repeat sample.
Pynn's Brook	Pynn's Brook	Pynn's Brook	W	SW	64	Aug 20, 2009	F2	Total coliform or Escherichia (E. coli) detected AND repeat samples can not be taken as required.
Red Bay	Red Bay	Northern Brook	L	SW	227	Sep 01, 1994	E2	No free chlorine residual detected in the water distribution system.
Riverhead	Riverhead (St. Mary's Bay)	Well Field	SJ	GW	220	Dec 22, 2011	C1	Disinfection system is off, due to maintenance or mechanical failure.
Rocky Harbour	Rocky Harbour	Gull Pond	W	SW	978	May 14, 2012	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Rose Blanche-Harbour Le Cou	Rose Blanche-Harbour Le Cou	Rose Blanche Brook	W	SW	547	May 11, 2012	C2	Disinfection system is off, due to lack of chlorine or other disinfectant.
Rushoon	Rushoon	Big Pond Brook	E	SW	319	Mar 28, 2000	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Gan	SW	315	Aug 17, 2005	A	Water Supply has no disinfection system.
Sheaves Cove	Sheaves Cove	Unnamed Brook	W	SW	66	Sep 08, 2008	C1	Disinfection system is off, due to maintenance or mechanical failure.
Sheaves Cove	Sheaves Cove	Drilled	W	GW	59	Sep 08, 2011	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	W	GW	34	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	W	GW		Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove East	#3 Well - Bernard Brake Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4 Well - Nancy Rowe Well	W	GW		Jul 25, 2011	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.
Shoe Cove	Shoe Cove	Second Pond	Gan	SW	198	May 25, 2005	B3	Chlorination system is turned off by operator, due to lack of funds to operate.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Bursery Well	SJ	GW	73	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead	#4 Well - Leonard King Well	SJ	GW	182	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	SJ	GW	32	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#7 Well - Gin Badcock Well	SJ	GW	53	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	SJ	GW	64	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#9 Well - Walter Reynolds Well	SJ	GW	85	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Snook's Arm	Snook's Arm	NFLD Hydro Penstock	Gan	SW	10	Feb 20, 1991	A	Water Supply has no disinfection system.
Sop's Arm	Sop's Arm	Little Tickle Pond	W	SW	224	Jan 01, 1990	E2	No free chlorine residual detected in the water distribution system.
South Dildo	South Dildo	#5 Well - Calvin Reid Well	SJ	GW	49	Apr 23, 2003	C1	Disinfection system is off, due to maintenance or mechanical failure.
South River	South River	Brigus Long Pond (to Brigus)	SJ	SW	92	Apr 09, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Southern Harbour	Southern Harbour	Brigades Pond	E	SW	474	Jan 31, 2011	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
St. Andrews	St. Andrew's	#1 Well	W	GW	66	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Andrews	St. Andrew's	#2 Well	W	GW	98	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Andrews	St. Andrew's East	#3 Well	W	GW	33	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Andrews	Air Strip Road	#4 Well Strip Road Well	W	GW	7	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Anthony Bight	St. Anthony Bight	Cabbox Pond	W	SW	147	Oct 22, 1997	E2	No free chlorine residual detected in the water distribution system.
St. Bernard's-Jacques Fontaine	St. Bernard's-Jacques Fontaine	Rattle Brook	E	SW	525	Oct 10, 2006	E2	No free chlorine residual detected in the water distribution system.
St. Bride's	St. Bride's	North Side Brook	SJ	SW	386	Jan 01, 1989	A	Water Supply has no disinfection system.
St. Bride's	St. Bride's	South Side Brook	SJ	SW		Jan 01, 1989	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Joseph's	St. Joseph's S.M.B.	Drilled	SJ	GW	54	Jun 23, 2000	A	Water Supply has no disinfection system.
St. Judes	St. Judes	Uncle Arthur Brook	W	SW	35	Jan 24, 2005	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
St. Judes	St. Judes	Chute Brook	W	SW	24	Dec 16, 2011	E2	No free chlorine residual detected in the water distribution system.
St. Lunaire-Griquet	St. Lunaire-Griquet	Joe's Pond	W	SW	666	Aug 01, 2011	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
St. Mary's	St. Mary's	Wellfield	SJ	GW	450	Jul 31, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
St. Patricks	St. Patricks	David Joy Well	Gan	GW	37	Feb 20, 1991	A	Water Supply has no disinfection system.
Steady Brook	Steady Brook	Steady Brook	W	SW	394	May 15, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Straitsview	Straitsview	Saddle Hill Pond	W	SW	105	Jun 17, 1998	E2	No free chlorine residual detected in the water distribution system.
Swift Current	Swift Current	Drilled	E	GW	21	Apr 30, 1999	A	Water Supply has no disinfection system.
Swift Current	Swift Current	Black Duck Pond	E	SW		Apr 30, 1999	A	Water Supply has no disinfection system.
Thornlea	Thornlea	Big Bakeapple Pond	E	SW	119	Dec 16, 2011	E2	No free chlorine residual detected in the water distribution system.
Tilt Cove	Tilt Cove	Castle Rock Pond	Gan	SW	7	Feb 20, 1991	A	Water Supply has no disinfection system.
Tompkins	Tompkins	Greg Wall Well	W	GW	87	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Trepassey	Trepassey	Miller's Pond	SJ	SW	763	Jun 23, 2000	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Trepassey	Trepassey	Miller's Pond	SJ	SW	763	Jun 23, 2000	F3	Total coliforms detected and confirmed in repeat sample.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	ISSUED_DATE	REASON_CODE	REASON
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	W	GW	49	Mar 21, 2006	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIassac Well	W	GW	52	Jul 08, 2003	E2	No free chlorine residual detected in the water distribution system.
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	W	GW	41	Sep 19, 2006	E2	No free chlorine residual detected in the water distribution system.
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	W	GW	22	Jul 13, 2003	E2	No free chlorine residual detected in the water distribution system.
Wabana	Wabana	Middleton Ave	SJ	GW		Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	#3 Yard West Mines Road	SJ	GW	224	Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	#4-West Mines Road	SJ	GW	271	Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	Normore Crescent East #1	SJ	GW	223	Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	Quigley's Line	SJ	GW	223	Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	Scotia #1	SJ	GW	223	Jun 23, 2000	A	Water Supply has no disinfection system.
Wabana	Wabana	St. Edward's Memorial St.	SJ	GW	60	Jun 23, 2000	A	Water Supply has no disinfection system.
West Bay	West Bay	Unnamed Brook	W	SW		Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
West St. Modeste	West St. Modeste	Well Field	L	GW	140	Nov 08, 2010	F2T	Total coliforms detected AND repeat samples can not be taken as required.
Westport	Westport	Western Brook Pond	Gan	SW	227	Feb 20, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Wild Cove	Wild Cove	Hedderson's Pond Brook	Gan	SW	88	Feb 20, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
William's Harbour	William's Harbour	Beaver Pond	L	SW	52	Jul 07, 2000	B1	Chlorination system is turned off by operator, due to taste.
Woodstock	Woodstock	Mill Pond	Gan	SW	199	Jul 26, 2007	E2	No free chlorine residual detected in the water distribution system.