



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Admirals Beach	Admiral's Beach	2 Well Fields	SJ	GW	130	Oct 13, 2010	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Avondale	Avondale	Lees Pond	SJ	SW	157	Feb 16, 2024	E2	No free chlorine residual detected in the water distribution system.
Baine Harbour	Baine Harbour	Baine Harbour Pond	E	SW	62	Dec 05, 2018	A	Water Supply has no disinfection system.
Baine Harbour	Baine Harbour	Dug	E	GW	50	Nov 14, 2003	A	Water Supply has no disinfection system.
Barachois Brook	Barachois Brook	Drilled	W	GW	124	Jan 30, 2024	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss.
Bartletts Harbour	Bartletts Harbour	Long Pond (same as Castors River North)	W	SW	105	Apr 29, 1998	E2	No free chlorine residual detected in the water distribution system.
Bay L'Argent	Bay L'Argent	Sugarloaf Hill Pond	E	SW	270	Aug 09, 2021	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Beaches	Beaches	Grassey Pond Brook	W	SW	42	Jul 07, 2016	C1	Disinfection system is off, due to maintenance or mechanical failure.
Bear Cove	Bear Cove	Lower Bear Cove	W	GW	20	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Bear Cove	Bear Cove	Upper Bear Cove	W	GW	9	Jun 22, 2000	E2	No free chlorine residual detected in the water distribution system.
Bellevue	Bellevue	Big Pond	E	SW	150	Sep 27, 2016	E2	No free chlorine residual detected in the water distribution system.
Bellevue Beach	Bellevue Beach	Unnamed Brook	E	SW	72	Sep 18, 1997	E2	No free chlorine residual detected in the water distribution system.
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	W	GW	57	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Benoit's Siding	Doyles	# 2 Well Doyles	W	GW	15	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Benton	Benton	Little Pond	Gan	SW	171	Mar 30, 2020	D1	Water distribution system is undergoing maintenance or repairs.
Bird Cove	Bird Cove (+Brig Bay)	Inner Gilmour Pond	W	SW	129	Aug 02, 2011	E2	No free chlorine residual detected in the water distribution system.
Biscay Bay	Biscay Bay	Unnamed Pond	SJ	SW	33	Jun 23, 2000	A	Water Supply has no disinfection system.
Black Duck Cove	Black Duck Cove	Long Pond - Black Duck Cove Intake	W	SW	124	Dec 17, 1997	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Branch	Branch (Backup Supply)	Valley Pond (Backup Supply)	SJ	SW	247	Jan 01, 1989	A	Water Supply has no disinfection system.
Brent's Cove	Brent's Cove	Paddy's Pond	Gan	SW	160	Feb 20, 1991	E2	No free chlorine residual detected in the water distribution system.
Brig Bay	Brig Bay	Inner Gilmour Pond	W	SW		Aug 02, 2011	E2	No free chlorine residual detected in the water distribution system.
Brigus South	Dunphey's Hill area	#2 Well Dunphey's Hilll	SJ	GW	32	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Brigus South	Forge Hill area	#1 Well Forge Hill	SJ	GW	30	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Brigus South	Near highway	#3 Well Main Road	SJ	GW	20	May 30, 2003	B1	Chlorination system is turned off by operator, due to taste.
Burlington	Burlington	Eastern Island Pond	Gan	SW	320	May 22, 2018	E2	Partial - From Brad Newbury to end of line. - No free chlorine residual detected in the water distribution system.
Burnt Islands	Burnt Islands	Long Lake	W	SW	651	Aug 08, 2019	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, interconnections, minor power outage or other pressure loss.
Campbellton	Campbellton	Indian Arm Brook	Gan	SW	506	Jan 12, 2024	F4	Escherichia coli (E. coli) detected in an initial sample(s) is considered extensive and the water system has other known problems.
Cape Freels North	Cape Freels North	Long Pond	Gan	SW	112	Mar 14, 2008	C1	Partial - - Disinfection system is off, due to maintenance or mechanical failure.
Carbonear	Carbonear	Island Pond / Flings Long Pond	SJ	SW	4739	Aug 22, 2023	D1	Water distribution system is undergoing maintenance or repairs.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Cartwright	Cartwright	Burdett's Pond	L	SW	464	May 23, 2006	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Castor River North	Castor River North	Long Pond (same as Bartletts Harbour)	W	SW	140	Jan 01, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Castor River South	Castor River South	Unnamed	W	SW	130	Jan 01, 1991	A	Water Supply has no disinfection system.
Chanceport	Chanceport	Bridger's Cove Pond	Gan	SW	37	Aug 11, 1989	E2	No free chlorine residual detected in the water distribution system.
Conche	Conche	Martin's Brook	W	SW	100	May 18, 2001	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Cook's Harbour	Cook's Harbour	Unnamed Pond	W	SW	140	Feb 01, 2023	C1	Disinfection system is off, due to maintenance or mechanical failure.
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	W	SW	19886	Apr 18, 2024	D1	Partial - Mount Bernard 61-95, O'Connell Drive 119 and Randolph Street. - Water distribution system is undergoing maintenance or repairs.
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	W	SW	19886	Sep 12, 2023	D1	Partial - Reids Road, Purchase Ave., Nevilles Road and Burtons Road - Water distribution system is undergoing maintenance or repairs.
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	W	SW	19886	Sep 08, 2023	D1	Partial - MacDonald Brown Drive, Filatre Street, Rowsell Street, Carriage, Woodrwo Ave, Hann Crescent, Tuma Ave, Silver Street extension, Snow Street #1, Carberry's (63-95), Lundrigan Drive (64,65 & 68) - Water distribution system is undergoing maintenance or repairs.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	W	SW	19886	Aug 28, 2023	D1	Partial - Valley Road #'s 59-101 Mays Road French's Road #'s 1-15 Citadel Drive # 10 Mt. Batten Road Cranes Avenue O'Connell Drive #'s 195, 233,243,& 245A - Water distribution system is undergoing maintenance or repairs.
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	W	SW	19886	Jun 21, 2023	D1	Partial - Mount Bernard Avenue #'s 29-55 Wellington Street # 1 Victoria Street # 3 - Water distribution system is undergoing maintenance or repairs.
Cottrell's Cove	Cottrell's Cove	Cottrell's Pond	Gan	SW	110	May 14, 2019	E2	No free chlorine residual detected in the water distribution system.
Cox's Cove	Cox's Cove	Cox's Brook	W	SW	600	Apr 17, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Deep Bight	Deep Bight	Deep Bight River	E	SW	176	Dec 04, 2018	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Dover	Dover	Hare Bay Pond	Gan	SW	673	Dec 19, 2022	E2	No free chlorine residual detected in the water distribution system.
Eddies Cove West	Eddies Cove West	Unnamed	W	SW	49	Apr 10, 2003	B3	Partial - Existing Boil Advisory since before 1991. Letter issued by Brian Moores. - Chlorination system is turned off by operator, due to lack of funds to operate.
Englee	Englee	Island Cove Pond	W	SW	583	Jan 24, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Flat Bay	Flat Bay (East)	#1 Well	W	GW	58	Mar 05, 2010	B4	Chlorination system is turned off by operator, due to Non-consumption Order.
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Gan	SW	240	Feb 28, 2024	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Forresters Point	Forresters Point	Rudges Pond	W	SW	202	May 28, 2020	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Forresters Point	Forresters Point	Rudges Pond	W	SW	202	Aug 18, 2021	F3	Total coliforms detected and confirmed in repeat sample.
Fox Cove-Mortier	Fox Cove-Mortier	Rock Pond	E	SW	7	Dec 18, 2019	D1	Water distribution system is undergoing maintenance or repairs.
Fox Roost-Margaree	Fox Roost-Margaree	Drilled Well and Margaree Pond	W	GW	334	Jan 30, 2015	F3	Total coliforms detected and confirmed in repeat sample.
Francois	Francois	Our Pond	W	SW	114	Apr 09, 1997	A	Water Supply has no disinfection system.
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	SJ	GW	95	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	SJ	GW	37	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.
Gallants	Gallants	Gallant's Brook	W	SW	59	May 01, 1997	A	Water Supply has no disinfection system.
Gaskiers	Gaskiers-Point La Haye	Big Hare Hill Pond	SJ	SW	290	Nov 08, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Gaultois	Gaultois	Piccaire Pond	Gan	SW	150	Oct 16, 2001	C1	Disinfection system is off, due to maintenance or mechanical failure.
Glenburnie-Birchy Head-Shoal Brook	Glenburnie-Birchy Head-Shoal Brook	Croucher's Brook	W	SW	60	Apr 03, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Goobies	Goobies	Water Pond	E	SW	77	Sep 05, 2014	F3	Total coliforms detected and confirmed in repeat sample.
Goose Cove East	Goose Cove East	Jack's Pond	W	SW	157	Aug 31, 1999	E2	No free chlorine residual detected in the water distribution system.
Grand Le Pierre	Grand Le Pierre	Nip Nose Pond	E	SW	260	Oct 10, 1997	E2	No free chlorine residual detected in the water distribution system.
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	SJ	GW	37	Jun 23, 2000	C1	Disinfection system is off, due to maintenance or mechanical failure.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Grates Cove	Grates Cove North End	#3 Frank Janes Well	SJ	GW	41	Jul 03, 2014	C1	Disinfection system is off, due to maintenance or mechanical failure.
Great Brehat	Great Brehat	Little Steady Pond	W	SW	87	Dec 17, 1997	E2	No free chlorine residual detected in the water distribution system.
Great Codroy	Great Codroy East	#1 Well	W	GW	30	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Great Codroy	Great Codroy West	#2 Well	W	GW	20	Jun 22, 2000	E2	No free chlorine residual detected in the water distribution system.
Green Island Brook	Green Island Brook	Green Island Brook	W	SW	161	Aug 19, 2021	F3	Total coliforms detected and confirmed in repeat sample.
Grey River	Grey River	Big Charlie's Pond	W	SW	100	Feb 20, 1997	A	Water Supply has no disinfection system.
Harbour Breton	Harbour Breton	Connaigra Pond, Hutchings Pond	Gan	SW	1411	Jul 14, 2023	E1	Partial - Deadman's Cove Park Only - Whole town on BWA until July 24th, partial BWA for the park remains in place - Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Head Pond	E	SW	100	Nov 20, 2003	A	Water Supply has no disinfection system.
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Well	E	GW		Jan 16, 2024	A	Water Supply has no disinfection system.
Hare Bay	Hare Bay (+Dover)	Hare Bay Pond	Gan	SW	1031	Dec 19, 2022	E2	No free chlorine residual detected in the water distribution system.
Harry's Harbour	Harry's Harbour	#1C Well - Northeast Well	Gan	GW	63	May 24, 2018	E2	No free chlorine residual detected in the water distribution system.
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Gan	GW	26	Oct 25, 2018	E2	No free chlorine residual detected in the water distribution system.
Harry's Harbour	Harry's Harbour	#3 Well - South Well	Gan	GW	43	Oct 25, 2018	E2	No free chlorine residual detected in the water distribution system.
Heart's Delight-Islington	Heart's Delight-Islington	Long Pond	SJ	SW	700	Aug 02, 2023	C1	Disinfection system is off, due to maintenance or mechanical failure.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Hermitage	Hermitage-Sandyville	Granfer's Pond	Gan	SW	450	Dec 19, 2012	E2	Partial - 2 Harbor View Road site only - No free chlorine residual detected in the water distribution system.
Howley	Howley	Sandy Lake	W	SW	221	Dec 19, 2016	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Hughes Brook	Hughes Brook	Reservoir	W	SW	156	Apr 17, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Irishtown-Summerside	Irishtown	Irishtown Brook	W	SW	714	Mar 18, 2022	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Irishtown-Summerside	Summerside	Pynn's Pond	W	SW	714	Oct 27, 2021	D1	Water distribution system is undergoing maintenance or repairs.
Jackson's Arm	Jackson's Arm	Unnamed Brook	W	SW	320	Apr 01, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Jackson's Cove-Langdon's Cove-Silverdale	Silverdale, Nickey's Nose Cove	Nickey's Nose Cove Pond	Gan	SW	40	May 30, 2014	F3	Total coliforms detected and confirmed in repeat sample.
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Gan	GW	20	Dec 07, 2023	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Jean de Baie	Jean de Baie	#1 Well	E	GW	173	Jan 01, 1996	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Keels	Keels	Boland's Pond	E	SW	42	Apr 04, 2024	D1	Water distribution system is undergoing maintenance or repairs.
La Poile	La Poile	Black Duck Pond	W	SW	103	Jan 01, 1995	B1	Chlorination system is turned off by operator, due to taste.
Lamaline	Lamaline	Upper Hodges Pond	E	SW		Jul 20, 2015	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Lance Cove	Lance Cove	Local Service District Well	SJ	GW	130	Sep 04, 2019	A	Water Supply has no disinfection system.
Lawn	Lawn	Brazil Pond	E	SW	672	Dec 13, 2019	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Little Harbour East	Little Harbour East (Placentia Bay)	Unnamed Pond	E	SW	115	Jan 01, 1996	E2	No free chlorine residual detected in the water distribution system.
Little St. Lawrence	Little St. Lawrence	Butler's Brook (2 Intakes)	E	SW	125	May 23, 1999	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Lower Lance Cove	Lower Lance Cove	Big Long Pond	E	SW	97	Aug 02, 2010	E2	No free chlorine residual detected in the water distribution system.
Lushes Bight-Beaumont-Beaumont North	Lushes Bight, Beaumont	Milkboy's Pond/Gull Pond	Gan	SW	140	Aug 10, 2023	D1	Water distribution system is undergoing maintenance or repairs.
Marysvale	Marysvale, Long Pond	Drilled	SJ	GW		Feb 01, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Mattis Point	Mattis Point	Drilled	W	GW	87	Apr 10, 2003	C1	Disinfection system is off, due to maintenance or mechanical failure.
Mclvers	Mclvers	Mclvers Brook	W	SW	546	Apr 17, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Meadows	Meadows, Summerside West	Meaters Pond	W	SW	649	Apr 15, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Middle Arm	Middle Arm	Dam Pond Brook	Gan	SW	476	Sep 15, 2008	C1	Disinfection system is off, due to maintenance or mechanical failure.
Milltown-Head of Bay D'Espoir	Milltown, Head of Bay D'Espoir	Jersey Pond	Gan	SW	789	Apr 19, 2024	F3	Partial - Canada Post to end of Milltown - Total coliforms detected and confirmed in repeat sample.
Ming's Bight	Ming's Bight	Middle Brook Pond	Gan	SW	250	Dec 14, 2021	C1	Disinfection system is off, due to maintenance or mechanical failure.
New-Wes-Valley	Wesleyville-Badger's Quay-Pool's Island, Brookfield-Poundcove-Newtown-Templeman	Little Northwest Pond	Gan	SW	2265	Jan 24, 2022	E2	Partial - New Town Area - No free chlorine residual detected in the water distribution system.
Newman's Cove	Newman's Cove	Heale Pond Brook	E	SW	156	Mar 26, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Nippers Harbour	Nippers Harbour	Blackhead Pond Brook	Gan	SW	128	Nov 25, 1996	E2	No free chlorine residual detected in the water distribution system.
North Harbour	North Harbour	Grandfather's Pond	E	SW		Jan 01, 1996	E2	No free chlorine residual detected in the water distribution system.
O'Donnells	O'Donnell's	Well Field	SJ	GW	150	Nov 06, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Pacquet	Pacquet	Big Brook	Gan	SW	184	May 25, 2020	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Parson's Pond	Parson's Pond	Cold Brook	W	SW	383	Apr 05, 2019	D1	Water distribution system is undergoing maintenance or repairs.
Petit Forte	Petit Forte	Reddy's Pond	E	SW	57	Jan 01, 1996	C1	Disinfection system is off, due to maintenance or mechanical failure.
Petley	Petley	Drilled + Dug Reservoir	E	GW	80	Jul 28, 2014	D1	Water distribution system is undergoing maintenance or repairs.
Phillips Head	Phillips Head	Dogberry Brook	Gan	SW		Apr 21, 2021	E2	No free chlorine residual detected in the water distribution system.
Piccadilly Head	Piccadilly Head (+West Bay)	Unnamed Brook	W	SW	139	Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	W	GW		Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	W	GW		Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Pidgeon Cove-St. Barbe	Pigeon Cove - St. Barbe	Long Pond	W	SW	155	Jul 19, 2023	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
Plum Point	Plum Point	Grand Pond	W	SW	100	Dec 17, 1997	E2	No free chlorine residual detected in the water distribution system.
Point Lance	Point Lance	Unnamed Pond	SJ	SW	105	Jan 01, 1989	A	Water Supply has no disinfection system.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Pollards Point	Pollards Point, Country Cove	Country Cove Pond	W	SW	252	Aug 17, 2015	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Pollards Point	Pollards Point East	George Ricks Pond	W	SW		Jan 01, 1987	A	Water Supply has no disinfection system.
Port Albert	Port Albert	Beaverton Pond	Gan	SW	69	May 31, 2023	Z	None Listed
Port Kirwan	North Side	Dug Well / Drilled Well	SJ	GW	65	Dec 03, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Port Kirwan	Port Kirwan	Developed Spring	SJ	GW		Feb 01, 2013	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Port Rexton	Port Rexton	#1 Well - Lois Long Well	E	GW	13	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Port Rexton (Seasonal Use)	#2 Well - Edmund Brown's Well	E	GW	11	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Hunchback Hill	#3 Well - Harold Vivian's Well	E	GW	14	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Ship Cove	#5 Well - Mabel Clarke's Well	E	GW	10	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Ship Cove	#6 Well - Banister's Well	E	GW	5	Sep 21, 2001	A	Water Supply has no disinfection system.
Port Rexton	Champneys Arm	Champney's Arm Well	E	GW	20	Sep 21, 2001	A	Water Supply has no disinfection system.
Portugal Cove South	Portugal Cove South	Wrights Brook	SJ	SW	150	Jul 30, 2019	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Pynn's Brook	Pynn's Brook	Pynn's Brook	W	SW	75	Mar 10, 2016	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Serviced	Issue Date	Reason Code	Reason
Random Sound West	North West Brook, Ivany Cove	#1 Well - Cabot Road South Well	E	GW	22	Jul 30, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Random Sound West	North West Brook, Ivany Cove	#2 Well	E	GW	27	Oct 01, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Random Sound West	North West Brook, Ivany Cove	#3 Well - Harbour Well	E	GW	35	Jul 30, 2012	E2	No free chlorine residual detected in the water distribution system.
Red Bay	Red Bay	Northern Brook	L	SW	192	Jul 08, 2022	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Red Harbour	Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	E	GW	191	Feb 05, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Rigolet	Rigolet	Rigolet Pond	L	SW	269	Nov 08, 2018	C1	Disinfection system is off, due to maintenance or mechanical failure.
Rushoon	Rushoon	Big Pond Brook	E	SW	288	Jul 14, 2015	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Seal Cove (FB)	Seal Cove, F.B.	Big Black Duck Pond	Gan	SW	263	Aug 17, 2005	A	Water Supply has no disinfection system.
Sheaves Cove	Sheaves Cove	Unnamed Brook	W	SW	60	Sep 08, 2008	C1	Disinfection system is off, due to maintenance or mechanical failure.
Sheaves Cove	Sheaves Cove	Drilled	W	GW	40	Sep 08, 2011	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	W	GW	308	Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	W	GW		Jun 21, 2000	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove East	#3 Well - Bernard Brake Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	W	GW		Jun 21, 2002	E2	No free chlorine residual detected in the water distribution system.
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	W	GW		Jan 08, 2021	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Shoe Cove	Shoe Cove	Second Pond	Gan	SW	161	May 25, 2005	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Smith's Harbour	Smith's Harbour	Fleshetts Brook	Gan	SW	145	Dec 10, 2019	C1	Disinfection system is off, due to maintenance or mechanical failure.
Sop's Arm	Sop's Arm	Little Tickle Pond	W	SW	160	Jan 01, 1990	E2	No free chlorine residual detected in the water distribution system.
South Dildo	South Dildo	#5 Well - Calvin Reid Well	SJ	GW	125	Apr 23, 2003	C1	Disinfection system is off, due to maintenance or mechanical failure.
Southern Harbour	Southern Harbour	Brigades Pond	E	SW	534	Jun 27, 2018	E2	No free chlorine residual detected in the water distribution system.
St. Anthony Bight	St. Anthony Bight	Cabbox Pond	W	SW	128	Oct 22, 1997	E2	No free chlorine residual detected in the water distribution system.
St. Bernard's-Jacques Fontaine	St. Bernard's-Jacques Fontaine	Rattle Brook	E	SW	470	Oct 05, 2020	E2	No free chlorine residual detected in the water distribution system.
St. Bride's	St. Bride's	North Side Brook	SJ	SW	110	Jan 01, 1989	A	Water Supply has no disinfection system.
St. Bride's	St. Bride's	South Side Brook	SJ	SW	140	Jan 01, 1989	C1	Disinfection system is off, due to maintenance or mechanical failure.
St. Joseph's	St. Joseph's S.M.B.	Drilled	SJ	GW	54	Jun 23, 2000	A	Water Supply has no disinfection system.
St. Judes	St. Judes	Uncle Arthur Brook	W	SW	32	Jan 24, 2005	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
St. Judes	St. Judes	Chute Brook	W	SW	27	Dec 16, 2011	E2	No free chlorine residual detected in the water distribution system.
St. Lewis	St. Lewis	Tub Harbour Pond	L	SW	190	Aug 12, 2020	F3	Total coliforms detected and confirmed in repeat sample.
St. Mary's	St. Mary's	Wellfield	SJ	GW	347	Jul 31, 2008	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
St. Patricks	St. Patricks	David Joy Well	Gan	GW	29	Feb 20, 1991	A	Water Supply has no disinfection system.
St. Shott's	St. Shott's	Unnamed Pond	SJ	SW	81	Jul 08, 2022	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Stephenville	Stephenville	Well Field	W	GW	6719	Mar 12, 2024	D1	Partial - #2- #28 Bruce Blvd, Evergreen, and Capri Court. - Water distribution system is undergoing maintenance or repairs.
Stoneville	Stoneville	Dog Bay Pond Brook	Gan	SW	317	Jun 18, 2021	F3	Total coliforms detected and confirmed in repeat sample.
Straitsview	Straitsview	Saddle Hill Pond	W	SW	100	Jun 17, 1998	E2	No free chlorine residual detected in the water distribution system.
Swift Current	Swift Current (Hollett's Point)	Drilled	E	GW	19	Apr 20, 2018	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Thornlea	Thornlea	Big Bakeapple Pond	E	SW	101	Dec 16, 2011	E2	No free chlorine residual detected in the water distribution system.
Tilt Cove	Tilt Cove	Castle Rock Pond	Gan	SW	5	Feb 20, 1991	A	Water Supply has no disinfection system.
Tompkins	Tompkins	Greg Wall Well	W	GW	90	Jul 09, 2010	C1	Disinfection system is off, due to maintenance or mechanical failure.
Torbay	Torbay	North Pond	SJ	SW	2760	Apr 12, 2024	D1	Water distribution system is undergoing maintenance or repairs.
Trepassey	Trepassey	Miller's Pond	SJ	SW	570	May 29, 2018	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Triton	Triton, Jim's Cove, Card's Harbour	Triton Pond	Gan	SW	998	Oct 04, 2012	E2	Partial - unable to get chlorine residuals (harbour Road) partial BWA - No free chlorine residual detected in the water distribution system.

Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
Upper Amherst Cove	Upper Amherst Cove	Drilled	E	GW	36	May 29, 2012	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	W	GW	47	Mar 21, 2006	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIssac Well	W	GW	32	Jul 08, 2003	E2	No free chlorine residual detected in the water distribution system.
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	W	GW	30	Sep 19, 2006	E2	No free chlorine residual detected in the water distribution system.
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	W	GW	22	Jul 13, 2003	E2	No free chlorine residual detected in the water distribution system.
Wabana	Wabana	Middleton Ave	SJ	GW		May 02, 2013	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Wabana	Wabana	#3 Yard West Mines Road	SJ	GW	2346	May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	#4-West Mines Road	SJ	GW		May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	Normore Crescent East #1	SJ	GW		May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	Quigley's Line	SJ	GW		May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	Scotia #1	SJ	GW		May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	St. Edward's Memorial St.	SJ	GW		May 02, 2013	D2	A cross connection is discovered in the distribution system.
Wabana	Wabana	Mixed Supplies	SJ	GW		May 02, 2013	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.



Boil Water Advisories for Public Water Supplies in Newfoundland and Labrador

April 22, 2024

Community	Serviced Area	Source Name	SNL Region	Supply Type	Population Served	Issue Date	Reason Code	Reason
West Bay	West Bay	Unnamed Brook	W	SW		Sep 28, 2010	B3	Chlorination system is turned off by operator, due to lack of funds to operate.
Westport	Westport	Western Brook Pond	Gan	SW	220	Feb 20, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Whitbourne	Whitbourne	Hodges River	SJ	SW	797	Jul 24, 2019	E2	No free chlorine residual detected in the water distribution system.
Wild Cove	Wild Cove	Hedderson's Pond Brook	Gan	SW	66	Feb 20, 1991	E1	Water entering distribution system or facility, after a minimum 20 minute contact time does not have a free chlorine residual of at least 0.3 mg/l or equivalent CT value.
Woodstock	Woodstock	Mill Pond	Gan	SW	190	Jul 26, 2007	E2	No free chlorine residual detected in the water distribution system.