

Boil Water Advisories Lifted in the Past 30 Days for Public Water Supplies in Newfoundland and Labrador

Date Created: May-21-2012 19:00

COMMUNITY_NAME	SERVICED_AREA	SOURCE_NAME	REGION_GSL	SUPPLY_TYPE	POPULATION_SERVICED	LIFTED_DATE	ISSUED_DATE	REASON_CODE	REASON
Burin	Burin (+Lewin's Cove)	Big Pond	E	SW	1118	May 18, 2012	May 10, 2012	D1	Partial - BWA(partial) for the area from The College of the North Atlantic to the beginning of Salt Pond - Water distribution system is undergoing maintenance or repairs.
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	L	GW	7572	May 18, 2012	May 16, 2012	D1	Partial - 17-31 MacDonald Drive, 22-36 MacDonald Drive - Water distribution system is undergoing maintenance or repairs.
Lewin's Cove	Lewin's Cove	Big Pond	E	SW	566	May 18, 2012	May 10, 2012	D1	Partial - BWA(partial) for the area from The College of the North Atlantic to the beginning of Salt Pond - Water distribution system is undergoing maintenance or repairs.
Millertown	Millertown	Water Pond	Gan	SW	100	May 18, 2012	Apr 17, 2012	E2	No free chlorine residual detected in the water distribution system.
Cow Head	Cow Head	Short Cat Path Pond	W	SW	440	May 11, 2012	Apr 30, 2012	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Hawke's Bay	Hawke's Bay	Torrent River	W	SW	391	May 11, 2012	May 03, 2012	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Irishtown-Summerside	Irishtown	Irishtown Brook	W	SW	1258	May 11, 2012	Apr 13, 2012	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Irishtown-Summerside	Summerside	Pynn's Pond	W	SW	750	May 11, 2012	Apr 13, 2012	F2E	Escherichia coli (E. coli) detected AND repeat samples can not be taken as required.
Trinity Bay North	Little Catalina	Whirl Pond	E	SW	458	May 11, 2012	Apr 29, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Trinity Bay North	Melrose	Whirl Pond	E	SW	316	May 11, 2012	Apr 29, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Trinity Bay North	Port Union, Catalina (+Little Catalina)	Whirl Pond	E	SW	1481	May 11, 2012	Apr 29, 2012	C1	Disinfection system is off, due to maintenance or mechanical failure.
Corner Brook	Corner Brook (All of eastside, portion of westside) (+Massey Drive)	Trout Pond, Third Pond (2 intakes)	W	SW	15077	May 10, 2012	May 03, 2012	D1	Partial - Corner Brook Regional High and Corner Brook Curling Club - Water distribution system is undergoing maintenance or repairs.
King's Point	King's Point	Bulley's Pond	Gan	SW	670	May 10, 2012	May 03, 2012	F5	Escherichia coli (E. coli) detected and confirmed in repeat sample.
Reidville	Reidville	Humber Canal, Grand Lake	W	SW	480	May 10, 2012	Jan 03, 2012	D1	Water distribution system is undergoing maintenance or repairs.
Deep Bight	Deep Bight	Deep Bight Well Field	E	GW	164	May 03, 2012	Apr 14, 2006	D3	Inadequately treated water was introduced into the system due to fire flows, flushing operations, minor power outage or other pressure loss.
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	L	GW	7572	May 03, 2012	Apr 30, 2012	D1	Partial - Grand Street - Water distribution system is undergoing maintenance or repairs.
Cook's Harbour	Cook's Harbour	Unnamed Pond	W	SW	190	May 01, 2012	Apr 19, 2012	F2T	Total coliforms detected AND repeat samples can not be taken as required.